

BUILDING INSPECTION NOTICE

E-Complete

Permit #: 1 6 - 1 3 7 7 5 1 - S 1

LI:

Supervisor Tel: 408 535-6863

Confirmation #: 0 1 2 0 4 0 3 8

Received: 10/26/2016

By: Internet

Preferred:

Scheduled: 1 1 / 0 3 / 1 6

Tract: 4557

Lot: 51

of Units: 0

Map: 875 B 7

Address: 6372 MAYO DR SAN JOSE

Contact: ryan petersen

Phone: 4083188332

ETA Call: Y

Owner: RAJARAMAN SUMAN AND KRISHNAN ARCHANA

Contractor: SARAH ALEXANDER SOLARCITY CORPORATION

Work: (650)963-5100

Folder Name: ()

Subtype: 1 & 2 Family

Work Proposed: Photovoltaic

Comments:

Related Permits:

Insp Time: 1 : 00

Inspection time listed at the left includes 10 minutes travel time.

Next Inspections Suggested

Number of Units: 01

Time inspection completed

Code	Description	O K	P A	C N	N R	N N	R F	Code	Description	O K	P A	C N	N R	N N	R F
9 1 8	Electrical Final	X													

Inspection Code: OK = Approved, PA = Partial Approval, CN = Correction Notice, NR = Not Ready, NN = Not Necessary, RF = Re-Inspection Fee Due

Remarks: (918) 12 MODULES TO PVI 3.0 INVERTER TO BACK FED
 125 AMP PANEL WITH 100 AMP BREAKER WITH 20 AMP
 BREAKER. VERIFIED GROUNDING & WATER BOND

You have a total of 0 hour(s) remaining on this project as of Wednesday, November 02, 2016 11:34:20 AM.

Inspector's Signature: T. GALL

Print: T. GALL

Date: 11 / 03 / 16

Page: 1 of 1